HydroClean Service
DESCALE • CONDITION WATER • FILTER • MONITOR

Boiler Log

Month/Yr_____

Date	Operator	Soft Water & FW Hardness 0-1 PPM	Conductivity 2500-3500 MHOS.	P/Total ALK 300-600/ Max 1000 PPM	Phospate/ Polymer 20-60 PPM	Sulfite 20-40 PPM	Cond. pH 8.0-8.8	Cond. Conductivity Record	Comments